

**Loxahatchee River District
Rolling Hills Subdivision Gravity Sewer, Lift Station,
& Force Main**

Addendum Number 4

November 19, 2021

The following clarifications and modifications are hereby made to the bidding documents for the above referenced project.

Acknowledge receipt of the addendum by inserting its number on Page 17 of the bid. Failure to do so may subject the bidder to disqualification.

General

Item 4-1 The following are questions asked after the pre-bid and the corresponding answers. As the deadline for questions has now passed, no further questions will be answered via addendum.

Questions

1. Bid items 26, 27 and 28 call for cleaning, televising, making point repairs, installing CIPP lining, and installing cleanouts of the existing laterals. Would the Contractor be allowed to remove and replace the existing clay laterals with new PVC laterals in lieu of this method?

Bidders should provide pricing for bid items as outlined currently on the bid proposal form. The removal and replacement of existing clay laterals with new PVC laterals may be considered with the selected Contractor after award.

2. What bid items should the manhole coating be covered under?

Manhole coating should be covered under Bid Item 12 -MISCELLANEOUS MANHOLE REPAIRS (INCLUDING MORTAR, PIPE CONNECTIONS, REINFORCEMENT STEEL, HOLES, CRACKS, JOINTS, AND LEAKS)

REVISE Specification Section 01200 Measurement and Payment Item L to read:

This item of work will be measured and paid for at the unit price per each manhole, regardless of depth or size (or number and flow rate of visible leaks encountered, pipe connections, manhole type or condition). Payment shall be made per unit price per each manhole for repairing mortar, pipe connections, reinforcing steel, holes, cracks, joints, or other repairs, as necessary. This item

also includes manhole coatings. Payment for this item shall be per each (EA) manhole.

3. The new lateral coming out of MH-14 is proposed to go under a decorative wall. Is the design intent to remove and replace this wall? If so, what bid item should this activity be included under?

If removal and replacement of a section of the wall will be required for the installation of the lateral, and it cannot be installed without disturbance of the wall, the bidder can accommodate for this cost under Pay Item No. 10 – Curb, Gutter, and Miscellaneous Restoration.

END OF ADDENDUM 4