Loxahatchee River District Lift Station Remote Telemetry Panels

Addendum Number 3

April 14, 2022

The following clarifications and modifications are hereby made to the bidding documents for the above referenced project.

Acknowledge receipt of the addendum by inserting its number on Page 17 of the bid. Failure to do so may subject the bidder to disqualification.

Specifications

Item 3-1 Amend Specification Section 16900 – Control Panels Item 1.1.C to read as follows:

The I&C supplier shall be a UL 508, UL 698A listed manufacturer. acceptable named manufacturers shall be limited to the following:

- 1. C.C. Control
- 2. DCR Engineering
- 3. Bug-a-Boo Controls
- 4. Revere Controls.
- Item 3-2 Amend Specification Section 16900 Control Panels Item 2.7.B to read as follows:

The I&C supplier shall be a UL 508, UL 698A listed manufacturer. acceptable named manufacturers shall be limited to the following:

- 1. Provide a Multitrode 10 segment conductance probe "candy stick" sensor with a signal cable. May be plugged directly to Xylem Multitrode Multi Smart pump controller. OR via a 10-segment relay by Multitrode MTIC model with 10 discrete outputs for use with the SEL pump controller.
- 2. Provide a barrier 10 segment relay and required wiring. Additionally provide a 316 SS mounting bracket and mounting hardware as required for 10 segment level sensor stick.

- Item 3-3 Amend Specification Section 16912 RTU Cell Base System Item 1.2.B to read as follows:
 - 8. UPS unit, Eaton 5P
 - **12.** Multitrode MTIC relay (only needed with the SEL pump Controller).


<u>Drawings</u>


Item 3-4 Replace Sheets E-2, E-3, E-4, and E-5 with the attached.

Questions from Bidders

- Q1: The spec states that the I&C supplier shall be a UL 508, UL 698A listed manufacturer. Can the supplier have the UL 508 certification but not be a UL 698A listed manufacturer?
- A1: Suppliers do not need to meet UL 698A certification. However, acceptable panel manufacturers are limited to the named list in specification Section 16900 Item 1.1.C. If the Contractor wishes to use a different panel manufacturer, they must get approval from the District.
- Q2: Due to the fact that we are required to provide a bid bond and a construction bond, if awarded, is the financial statement contained within the bid form necessary? Would a contractor be considered non-responsive if they left the financial statement blank?
- A2: The financial statement is a component of the Loxahatchee River District requirements. Therefore, it may be considered non-responsive if not included in the bid. Please follow all contract document requirements as stated to not be subject to disqualification.

END OF ADDENDUM 3








REGISTRATION NUMBERS C & W ENGINEERING INC. CA# 33315 MICHAEL A. GUIDA, P.E. 60755

E-3



NO	IES	FOR	WE

- LOCATION.
- MINIMUM PANEL AIC RATING SHALL BE 22,000A.

SPECIFIC ELECTRICAL NOTES

CELL BASED RTU	Н
PANEL SCHEMATICS	
SHEET 1	
	PANEL SCHEMATICS

NOTES FOR WELL RTU PANEL

1. PROVIDE RTU WITH SEL OR XYLEM PUMP CONTROLLER AND CELL BASED RADIO.

2. COORDINATE WITH ENGINEER AND OWNER LOCATION OF RTU IN REFERENCE TO EXISTING EQUIPMENT AT EACH INSTALLATION

MOUNT/INSTALL ONTO EXISTING H-FRAME EQUIPMENT RACK, PROVIDE 316SS HARDWARE AND 316SS UNISTRUT AS REQUIRED.

1 PUMP CONTROLLER SHALL BE AN SEL TRIPLEX PUMP CONTROLLER, OR XYLEM MULTISMART TRIPLEX PUMP CONTROLLER, NO EQUAL.





E-4

REGISTRATION NUMBERS C & W ENGINEERING INC. CA# 33315 MICHAEL A. GUIDA, P.E. 60755

MICHAEL A. GUIDA

License No: 60755



270 SOUTH CENTRAL BLVD., SUITE 207 JUPITER, FLORIDA 33458 PH. (561) 575-2005 Cert. No. 26960 Cert. No. 26960

