

Loxahatchee River District Lift Station Remote Telemetry Panels

Addendum Number 4

April 15, 2022

The following clarifications and modifications are hereby made to the bidding documents for the above referenced project.

Acknowledge receipt of the addendum by inserting its number on Page 17 of the bid. Failure to do so may subject the bidder to disqualification.

Specifications

Item 4-1 Amend Specification Section 16900 – Control Panels Item 1.2.C to read as follows:

The I&C supplier shall be a UL 508 listed manufacturer. ~~acceptable named manufacturers shall be limited to the following:~~

- ~~1. C.C. Control~~
- ~~2. DCR Engineering~~
- ~~3. Bug-a-Boo Controls~~
- ~~4. Revere Controls.~~

Clarifications

Item 4-2 Addendum 3 previously stated that panel manufacturers are limited to the named list in specification section 16900 Item 1.2.C. This addendum is to clarify that there is no approved list of named panel manufacturers. Panel manufactures must be UL 508 certified and qualified to perform the work as shown in the Contract Documents.

END OF ADDENDUM 4