



LOXAHATCHEE RIVER DISTRICT

2500 JUPITER PARK DRIVE, JUPITER, FLORIDA 33458

TEL: (561) 747-5700

FAX: (561) 747-9929

D. Albrey Arrington, Ph.D. EXECUTIVE DIRECTOR

loxahatcheeriver.org

SIMPLEX AND DUPLEX LPSS PUMP STATIONS

ITB # 23-001-00123

Pre-Bid Meeting Minutes

November 15, 2022

2:00 PM

1. Non-mandatory Pre-Bid Meeting:
2. Scope: General Information: It is the Loxahatchee River District's intent and the purpose of these specifications to secure a qualified vendor to furnish materials and supplies necessary to provide Residential – Simplex & Duplex Grinder Pump Stations, Commercial – Duplex Grinder Pump Stations, and Commercial – Duplex Low Flow Grinder Pump Stations for installation by others.
 - a. To specify requirements for Residential – Simplex & Duplex Grinder Pump Stations, Commercial – Duplex Grinder Pump Stations, and Commercial – Duplex Low Flow Grinder Pump Stations, and to cover the fabrication, assembly, shop testing, delivery of materials, equipment and appurtenances for complete pump stations including ~~valve box assembly and the~~ control panel as specified in District Standard Details LP-6 through LP-20. Refer to Exhibit I included as part of the bid documents for District Standard Details LP-6 through LP-20.
 - b. The vendor shall be the supplier of the submersible grinder lift station that meets District Standard Details LP-6 through LP-20. Refer to Exhibit I included as part of the bid documents for District Standard Details LP-6 through LP-20.
 - c. All equipment shall be furnished through the manufacturer of the submersible grinder lift station vendor who shall be responsible for the design, shop assembly, delivery and functioning of the equipment specified. The submersible grinder lift station manufacturer shall verify that each component of the grinder lift station system is compatible with all other components, that piping, conduit, conductor sizes are appropriate and that all devices necessary for proper operation of the equipment have been provided.

James D. Snyder
CHAIRMAN

Gordon M. Boggie
BOARD MEMBER

Stephen B. Rockoff
BOARD MEMBER

Dr. Matt H. Rostock
BOARD MEMBER

3. All equipment and materials provided under this contract shall comply with the standard details and specifications. No substitutions.
4. Bids may only be submitted via DemandStar.
5. Bids will be publicly opened in the Governing Board Room on November 22, 2022 at 2:00 pm.
6. Questions:
 - a. General Conditions 3.b. Confirm that you require a Palm Beach County Occupational License in addition to any other licenses required regardless of the location of the bidder? **Palm Beach County Occupational License is not required.**
 - b. General Conditions 10. Confirm whether bidders are required to be State of Florida Certified Electrical Contractor? **Bidders are not required to be State of Florida Certified Electrical Contractor.**
 - c. Is the valve box, piping and valves as shown on LP-6 and LP-9 to be supplied by the contract or the District? **The District**
 - d. Submit questions via email to Purchasing@lrecd.org