

SEPTAGE WASTE HAULER APPLICATION

1. Name of Business: _____

Owner(s): _____

Address of Business: _____

Phone number of Business: _____

Name/Title of contact at Business: _____

2. What type of wastes do you haul? Check all that apply.

- Domestic septage from residences
- Domestic septage from commercial/industrial
- Waste from restaurant grease traps
- Waste from sand traps from automotive service stations, car washes, truck maintenance facilities
- Waste from pits, tanks, traps from other commercial sources
- Cleaning waste solutions from waste bin (i.e. garbage cans, roll-offs, dumpsters, etc.) cleaning systems
- Not listed above. Specify: _____

***NOTE: Loxahatchee River District only accepts domestic sewage from sources within its service area. If you are applying to haul any type of wastes other than domestic sewage, you will not be permitted to haul and discharge at the Loxahatchee River District WWTF.

3. Waste Hauling Information

of Trucks operated by your business: _____

Capacity in Gallons

- 100-499
- 499-1000
- 1000-2000
- 2000-3500
- 3500-5000
- > 5000

4. Estimate of total number of loads to be disposed of per week: _____
(To be disposed of (or requesting to be disposed of) at the District's WWTF)

5. Estimate of total gallons to be disposed of per week: _____
(To be disposed of (or requesting to be disposed of) at the District's WWTF)

SEPTAGE WASTE HAULER APPLICATION

I certify under penalty of law that this document and all attachments were prepared under my direct supervision. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. Further, I have reviewed, understand, and agree to abide by the requirements stipulated in the District's written, Septage Waste Hauling & Disposal Standard Operating Procedure.

Owner: _____

Title: _____

Date: _____

Please complete and sign this application and mail to:

Loxahatchee River District
Attn: Industrial Pretreatment Department
2500 Jupiter Park Drive
Jupiter, Florida 33458
pretreatment@LRECD.org

SEPTAGE WASTE HAULER APPLICATION

The following procedures are Standard Operating Procedures for the hauling and discharge of domestic sewage at Loxahatchee River District's WWTF. The District accepts septage waste haulers Monday thru Friday between the hours of 9:00 AM and 4:00 PM.

1. All septic waste hauler drivers must notify the lead operator on duty (561-262-1863) before transporting waste to the plant. *****LEAD OPERATOR HAS THE RIGHT TO REFUSE WASTE IF PLANT BIOLOGICAL PROCESS IS UNSTABLE OR DURING A DECLARED EMERGENCY****
2. Operation Administration Assistant will notify lead operator once waste hauler driver arrives at the District's WWTF.
3. Each hauler is required to verify the address(s) the waste was hauled from to confirm that it is within the District service area, then do a grab sample of the waste while the plant operator is present. All waste shall have a pH within range of 6.5 to 8.5 standard units. If the pH is not within the required range, the hauler will not be permitted to discharge the waste to the District's WWTF.
4. Samples must be kept for a minimum of 48-hours in the Headworks sample refrigerator. All samples must, at a minimum, be labeled with time, septic hauler name and sampler name.
5. Check that all valves and related ground valve at the septage receiving station is in the proper operational position.
6. Waste hauler driver will connect tanker discharge hose to the septage receiving station influent cam lock fitting and briefly flush pipe with the non-potable water prior to discharging septic waste with the grinder and transfer pump in the "ON" position.
7. Before the flush is complete the septic hauler must open their discharge valve, while the operator slowly closes the non-potable valve. At this time, the flow totalizer can be reset. When the hauler closes the discharge valve of the tanker, the operator must record the final number on the totalizer.
8. The line must be flushed with non-potable water supply.
9. The septage receiving area must be cleaned after each septic hauler.
10. When the tanker truck has been emptied, the operator must ensure that the Trip Ticket for Septage Waste is completely and accurately filled out.

*****NOTE: To insure that only domestic septage from sources located within the District's service area boundaries are received, the septage waste hauler, shall provide the following: source name, source address, service type and estimated gallonage for each customer *****