

Loxahatchee River District

ITB # 26-001-00150

GENERATOR REPAIR AND MAINTENANCE

Addendum Number 2 (w/Bid Clarifications)

March 03, 2026

This document forms a part of the Contract Documents and modifies the original plans and specifications dated February 16, 2026 as noted below.

Acknowledge receipt of this Addendum by executing and returning acknowledgement form with your qualification submittal. Failure to do so may subject the bidder to disqualification.

This Addendum consists of ONE (1) page:

Bidder Question & Response:

1. Are any of the generators Medium Voltage?

Response: Our current generators are all 3-PH variable voltage up to 480V.

END OF ADDENDUM 2

Loxahatchee River District

ITB # 26-001-00150

GENERATOR REPAIR AND MAINTENANCE

ADDENDUM ACKNOWLEDGEMENT FORM

The undersigned Bidder acknowledges receipt of Addenda as listed below:

Receipt of Addendum No. 1 Date _____

Receipt of Addendum No. 2 Date _____

Firm: _____

By: _____

Title: _____

Please include this completed Addendum Acknowledgement Form with your Qualification